

Model Predictive Control of an Inverter With Output LC Filter for UPS Applications

Patricio Cortés, *Member, IEEE*, Gabriel Ortiz, Juan I. Yuz, *Member, IEEE*, José Rodríguez, *Senior Member, IEEE*, Sergio Vazquez, *Member, IEEE*, and Leopoldo G. Franquelo, *Fellow, IEEE*

Abstract—The use of an inverter with an output LC filter allows for generation of output sinusoidal voltages with low harmonic distortion, suitable for uninterruptible power supply systems. However, the controller design becomes more difficult. This paper presents a new and simple control scheme using predictive control for a two-level converter. The controller uses the model of the system to predict, on each sampling interval, the behavior of the output voltage for each possible switching state. Then, a cost function is used as a criterion for selecting the switching state that will be applied during the next sampling interval. In addition, an observer is used for load-current estimation, enhancing the behavior of the proposed controller without increasing the number of current sensors. Experimental results under linear and nonlinear load conditions, with a 5.5-kW prototype, are presented, verifying the feasibility and good performance of the proposed control scheme.

Index Terms—Power conversion, predictive control, uninterruptible power systems.

I. INTRODUCTION

THE CONTROL of inverters with an output LC filter has a special importance in applications where a high-quality voltage is needed. Such applications include distributed generation, energy-storage systems, stand-alone applications based on renewable energy, and uninterruptible power supplies (UPSs) [1], [2]. In these systems, it is desired, particularly for stand-alone applications and UPS systems [3], to achieve a good output-voltage regulation with any kind of load, being very important that the functionality of the system does not deteriorate under nonlinear loads, such as diode rectifiers.

The inclusion of an LC filter at the output of the inverter makes more difficult the controller design and controller parameters' adjustment. Several control schemes have been proposed for this converter, including deadbeat control [4]–[6], multiloop feedback control [7]–[9], adaptive control based on

bank resonant filters [10], [11], and repetitive-based controllers [12], [13]. Some tuning strategies have been presented, including H-infinity control design [14]. In most of these schemes, the output voltage and one of two currents are used by a cascaded control considering outer and inner control loops, with linear or nonlinear controllers, to generate the reference voltages and by an external modulator to generate the firing pulses for the power semiconductors.

Predictive control appears as an attractive alternative for the control of power converters due to its fast dynamic response [15]. Several control algorithms have been presented under the name of predictive control, as presented in [16]. The most well-known scheme is deadbeat control, and it has been applied to current control in inverters [17], [18], rectifiers [19], active filters [20], [21], power-factor preregulators [22], and UPSs [6], [23]. When implemented in a digital system, deadbeat control needs to be modified in order to improve robustness. Several modifications have been proposed in the last years [24]–[27] considering adaptive schemes, neural networks, and other changes that make the controller robust but more complex. Another approach is the model predictive control (MPC), also known as receding-horizon control; it uses a model of the system to predict the behavior of the variables until a certain horizon of time, and a cost function is used as criterion to select the optimal future actions [28]–[31]. Several works have introduced the models for power converters [32], [33], which can be used to develop new model predictive controllers, improving the performance of the system. MPC is a very flexible control scheme that allows the easy inclusion of system constraints and nonlinearities in the design stage of the controller. In MPC, different formulations of the cost function are possible, considering different norms and including several variables and weighting factors [15]. It is also possible to consider different prediction horizons, as shown in [34]. The inputs of the system can be considered continuous, by using a modulator to apply the optimal voltages, as presented in [28] and [35]. In order to simplify the implementation of MPC, the converter can be modeled as a system with a finite number of switching states, and only one time step horizon can be considered for the optimization, as presented for the current control in a matrix converter in [36] and [37], a three-phase inverter in [38] and [39], an active front-end rectifier in [40], a multilevel inverter in [41], and a flying capacitor converter in [42]. This way, all possible switching states can be evaluated online; then, the one that minimizes the cost function is selected.

This paper proposes a new and simple MPC scheme for a three-phase inverter with output LC filter. The controller uses

Manuscript received April 16, 2008; revised August 15, 2008 and December 29, 2008. First published February 27, 2009; current version published June 3, 2009. This work was supported in part by the Chilean National Fund of Scientific and Technological Development (FONDECYT) under Grant 1080443 and in part by the Universidad Técnica Federico Santa María.


P. Cortés, J. I. Yuz, and J. Rodríguez are with the Electronics Engineering Department, Universidad Técnica Federico Santa María, Valparaíso 110-V, Chile (e-mail: patricio.cortes@usm.cl).

G. Ortiz is with the Power Electronic Systems Laboratory, Eidgenössische Technische Hochschule Zürich, 8092 Zürich, Switzerland.

S. Vazquez and L. G. Franquelo are with the Department of Electronic Engineering, University of Seville, 41092 Seville, Spain (e-mail: svazquez@zipi.us.es).

Color versions of one or more of the figures in this paper are available online at <http://ieeexplore.ieee.org>.

Digital Object Identifier 10.1109/TIE.2009.2015750

Fig. 1. Three-phase inverter with output LC filter.

a model of the system to predict, on each sampling interval, the behavior of the output voltage for each possible switching state, and then, a cost function is used as a criterion for selecting the switching state that will be applied during the next sampling interval. There is no need of internal current-control loops and no modulators; the gate-drive signals are generated directly by the control. In addition, an observer is used for load-current estimation, enhancing the behavior of the proposed controller without increasing the number of current sensors.

II. CONVERTER MODEL

The three-phase inverter with output LC filter considered in this paper is shown in Fig. 1. The converter and filter models are presented here, and the load is assumed unknown.

The switching states of the converter are determined by the gating signals S_a , S_b , and S_c as follows:

$$S_a = \begin{cases} 1, & \text{if } S_1 \text{ on and } S_4 \text{ off} \\ 0, & \text{if } S_1 \text{ off and } S_4 \text{ on} \end{cases} \quad (1)$$

$$S_b = \begin{cases} 1, & \text{if } S_2 \text{ on and } S_5 \text{ off} \\ 0, & \text{if } S_2 \text{ off and } S_5 \text{ on} \end{cases} \quad (2)$$

$$S_c = \begin{cases} 1, & \text{if } S_3 \text{ on and } S_6 \text{ off} \\ 0, & \text{if } S_3 \text{ off and } S_6 \text{ on} \end{cases} \quad (3)$$

and can be expressed in vectorial form by

$$\mathbf{S} = \frac{2}{3} (S_a + \mathbf{a}S_b + \mathbf{a}^2S_c) \quad (4)$$

where $\mathbf{a} = e^{j(2\pi/3)}$.

The output-voltage space vectors generated by the inverter are defined by

$$\mathbf{v}_i = \frac{2}{3} (v_{aN} + \mathbf{a}v_{bN} + \mathbf{a}^2v_{cN}) \quad (5)$$

where v_{aN} , v_{bN} , and v_{cN} are the phase voltages of the inverter, with respect to the negative terminal of the dc-link N (see Fig. 1). Then, the load voltage vector \mathbf{v}_i can be related to the switching state vector \mathbf{S} by

$$\mathbf{v}_i = V_{dc}\mathbf{S} \quad (6)$$

where V_{dc} is the dc-link voltage.

Considering all the possible combinations of the gating signals S_a , S_b , and S_c , eight switching states and, consequently,





Fig. 2. Possible voltage vectors generated by the inverter.

Fig. 3. LC filter model.

eight voltage vectors are obtained. Note that $\mathbf{v}_0 = \mathbf{v}_7$, resulting in only seven different voltage vectors, as shown in Fig. 2.

Using modulation techniques like pulsewidth modulation, the inverter can be modeled as a continuous system. Nevertheless, in this paper, the inverter is considered as a nonlinear discrete system with only seven different voltage vectors as possible outputs.

Using vectorial notation, the filter current \mathbf{i}_f , the output voltage \mathbf{v}_c , and the output current \mathbf{i}_o can be expressed as space vectors and are defined as

$$\mathbf{i}_f = \frac{2}{3} (i_{fa} + \mathbf{a}i_{fb} + \mathbf{a}^2i_{fc}) \quad (7)$$

$$\mathbf{v}_c = \frac{2}{3} (v_{ca} + \mathbf{a}v_{cb} + \mathbf{a}^2v_{cc}) \quad (8)$$

$$\mathbf{i}_o = \frac{2}{3} (i_{oa} + \mathbf{a}i_{ob} + \mathbf{a}^2i_{oc}). \quad (9)$$

The LC filter is modeled as shown in the block diagram in Fig. 3. This model can be described by two equations, one that describes the inductance dynamics and the other describing the capacitor dynamics.

The equation of the filter inductance expressed in vectorial form is

$$L \frac{d\mathbf{i}_f}{dt} = \mathbf{v}_i - \mathbf{v}_c \quad (10)$$

where L is the filter inductance.

The dynamic behavior of the output voltage can be expressed by the following:

$$C \frac{d\mathbf{v}_c}{dt} = \mathbf{i}_f - \mathbf{i}_o \quad (11)$$

where C is the filter capacitance.

These equations can be rewritten as a state-space system as

$$\frac{d\mathbf{x}}{dt} = \mathbf{A}\mathbf{x} + \mathbf{B}\mathbf{v}_i + \mathbf{B}_d\mathbf{i}_o \quad (12)$$

where

$$\mathbf{x} = \begin{bmatrix} \mathbf{i}_f \\ \mathbf{v}_c \end{bmatrix} \quad (13)$$

$$\mathbf{A} = \begin{bmatrix} 0 & -1/L \\ 1/C & 0 \end{bmatrix} \quad (14)$$

$$\mathbf{B} = \begin{bmatrix} 1/L \\ 0 \end{bmatrix}$$

$$\mathbf{B}_d = \begin{bmatrix} 0 \\ -1/C \end{bmatrix}. \quad (15)$$

Variables \mathbf{i}_f and \mathbf{v}_c are measured, while \mathbf{v}_i can be calculated using (6), and \mathbf{i}_o is considered as an unknown disturbance. In this paper, the value of V_{dc} is assumed fixed and known.

The output of the system is the output voltage \mathbf{v}_c and written as a state equation

$$\mathbf{v}_c = [0 \quad 1]\mathbf{x}. \quad (16)$$

A. Discrete-Time Model of the Filter

A discrete-time model of the filter is obtained from (12) for a sampling time T_s and is expressed as

$$\mathbf{x}(k+1) = \mathbf{A}_q\mathbf{x}(k) + \mathbf{B}_q\mathbf{v}_i(k) + \mathbf{B}_{dq}\mathbf{i}_o(k) \quad (17)$$

where

$$\mathbf{A}_q = e^{\mathbf{A}T_s} \quad (18)$$

$$\mathbf{B}_q = \int_0^{T_s} e^{\mathbf{A}\tau}\mathbf{B}d\tau \quad (19)$$

$$\mathbf{B}_{dq} = \int_0^{T_s} e^{\mathbf{A}\tau}\mathbf{B}_d d\tau. \quad (20)$$

These equations are used as the predictive model in the proposed predictive controller.

In order to predict the output voltage using (17), the output current \mathbf{i}_o is needed, but usually, this current is not measured, and the load is unknown. A simple estimation of the load current can be calculated from filter-current and output-voltage measurements using the following equation obtained from (11):

$$\mathbf{i}_o(k-1) = \mathbf{i}_f(k-1) - \frac{C}{T_s}(\mathbf{v}_c(k) - \mathbf{v}_c(k-1)). \quad (21)$$

However, this estimation is very sensitive to noise in the measurements, because it is based on the derivative of the output voltage, so it will be preferred to use an observer such as the one presented in the next section.

III. LOAD-CURRENT OBSERVER

The load current depends on the load connected at the output of the filter which is unknown. However, some considerations can be taken in order to build an appropriate observer. These

considerations consist of assuming a certain dynamic behavior of the load current.

A simple consideration is to assume that the load current is changing very slowly, compared to the sampling frequency. Lets assume that the load current can be approximated as a constant, so its behavior is described by the following differential equation:

$$\frac{d\mathbf{i}_o}{dt} = 0. \quad (22)$$

Then, including this load-current model in the filter model, the system is described by the following state-space equations:

$$\frac{d}{dt} \underbrace{\begin{bmatrix} \mathbf{i}_f \\ \mathbf{v}_c \\ \mathbf{i}_o \end{bmatrix}}_{\mathbf{x}} = \underbrace{\begin{bmatrix} 0 & -\frac{1}{L} & 0 \\ \frac{1}{C} & 0 & -\frac{1}{C} \\ 0 & 0 & 0 \end{bmatrix}}_{\mathbf{A}} \underbrace{\begin{bmatrix} \mathbf{i}_f \\ \mathbf{v}_c \\ \mathbf{i}_o \end{bmatrix}}_{\mathbf{x}} + \underbrace{\begin{bmatrix} \frac{1}{L} \\ 0 \\ 0 \end{bmatrix}}_{\mathbf{B}} \mathbf{v}_i. \quad (23)$$

The output of this system are the two measured variables, the filter current and the output voltage, and is defined by the following equation:

$$\mathbf{y} = \underbrace{\begin{bmatrix} 1 & 0 & 0 \\ 0 & 1 & 0 \end{bmatrix}}_{\mathbf{C}} \underbrace{\begin{bmatrix} \mathbf{i}_f \\ \mathbf{v}_c \\ \mathbf{i}_o \end{bmatrix}}_{\mathbf{x}}. \quad (24)$$

A full-order observer for the system can be used to estimate the state vector \mathbf{x} . An observer is an open-loop model of the system which includes a correcting term based on the measured output. This is

$$\frac{d\hat{\mathbf{x}}}{dt} = \mathbf{A}\hat{\mathbf{x}} + \mathbf{B}\mathbf{v}_i + \mathbf{J}(\mathbf{y} - \hat{\mathbf{y}}) \quad (25)$$

where $\hat{\mathbf{y}} = \mathbf{C}\hat{\mathbf{x}}$ and \mathbf{J} is the so-called observer gain [43].

This equation can be rewritten as

$$\frac{d\hat{\mathbf{x}}}{dt} = \mathbf{A}_{\text{obs}}\hat{\mathbf{x}} + [\mathbf{B} \quad \mathbf{J}] \begin{bmatrix} \mathbf{v}_i \\ \mathbf{i}_f \\ \mathbf{v}_c \end{bmatrix} \quad (26)$$

where $\mathbf{A}_{\text{obs}} = \mathbf{A} - \mathbf{J}\mathbf{C}$. The output of the observer is the estimated load current

$$\hat{\mathbf{i}}_o = [0 \quad 0 \quad 1]\hat{\mathbf{x}}. \quad (27)$$

Note that the observer can be understood just as a filter which gives an estimate of the (unknown) load current $\hat{\mathbf{i}}_o$, based on measurements of the filter current \mathbf{i}_f , the output voltage \mathbf{v}_c , and the inverter voltage \mathbf{v}_i .

Matrix gain \mathbf{J} will define the observer dynamics. As a design parameter, it must take into account the tradeoff between bandwidth and noise rejection. In fact, such gain can be chosen to be *optimal* if we characterize the statistical properties of the noise, and then, the observer is designed as a steady-state Kalman filter [44]. A simpler alternative is to choose the observer gain such that the poles of the observer give dynamics several times faster than the open-loop system dynamics.




Fig. 4. Block diagram of the predictive controller.

IV. PROPOSED PREDICTIVE CONTROLLER

The use of MPC to control the power converter is proposed in this paper. MPC presents several advantages that make it suitable to control this kind of system: concepts are easy to understand, constraints and nonlinearities of the system can be easily included, and the desired behavior of the system is formulated as a cost function to be minimized. This paper takes into account an important restriction of the inverter, it can generate only seven different output-voltage vectors, and takes advantage of this restriction, making it possible to solve online the optimization problem of MPC. In these control schemes, an open-loop model is used for prediction and selection of the optimal actuations, but the use of a receding horizon provides the feedback to the control. This means that only the first element of the optimal actuation sequence is applied, and all the optimization is calculated again each sampling time.

The block diagram of the proposed predictive control for a three-phase inverter with output LC filter is shown in Fig. 4. Here, measurements of the output voltage $v_c(k)$ and the filter current $i_f(k)$ are used to predict, using (17), the value of the output voltage at the next sampling instant $v_c(k+1)$ for all the possible voltage vectors that the inverter generates.

Note that in order to obtain the prediction $v_c(k+1)$ from (17), an estimate of the (unmeasured) output current $i_o(k)$ is required. In fact, a comparison is presented in Section V with results obtained using the simple derivative approximation in (21) and the load-current observer presented in the previous section.

To choose the *optimal* voltage vector v_i to be applied by the inverter, the seven predictions obtained for $v_c(k+1)$ are compared using a cost function g . The voltage vector v_i that minimizes this function is then chosen and applied at the next sampling instant.

In this paper, we choose a cost function g expressed in orthogonal coordinates and defines the desired behavior of the system: To minimize the error in the output voltage

$$g = (v_{c\alpha}^* - v_{c\alpha})^2 + (v_{c\beta}^* - v_{c\beta})^2 \quad (28)$$

where $v_{c\alpha}^*$ and $v_{c\beta}^*$ are the real and imaginary parts of the output-voltage reference vector \mathbf{v}_c^* , while $v_{c\alpha}$ and $v_{c\beta}$ are the real and imaginary parts of the predicted output-voltage vector $\mathbf{v}_c(k+1)$.

This cost function has been chosen in order to obtain the lowest voltage error. However, additional constraints can be con-

TABLE I
PARAMETERS OF THE EXPERIMENTAL SETUP

Parameter	Value
DC link voltage V_{dc}	520 [V]
Filter inductance L	2.4 [mH]
Filter capacitor C	40 [μ F]
Sampling time T_s	33 [μ s]

sidered in this function, such as current limitation, switching-frequency reduction, and spectrum shaping.

When implemented in a real system, the time needed for performing all the calculations of the control algorithm introduces a one sampling time delay that has to be compensated as explained in [45].

V. EXPERIMENTAL RESULTS

The proposed predictive current-control strategy was tested experimentally using a Danfoss VLT5008 5.5-kW three-phase inverter with an output LC filter. The dc-link is fed by a three-phase diode-bridge rectifier. The inverter is controlled externally through an interface and protection card. A TMS320C6713 floating-point digital signal processor (DSP) was used for the control. A field-programmable-gate-array-based daughter card handles the analog-to-digital and digital-to-analog conversions and provides the digital outputs used as firing signals for power switches of the converter. The parameters of the system are shown in Table I.

In the implementation of the predictive-control algorithm, including the load-current observer, a minimum sampling time of $T_s = 33 \mu\text{s}$ was achieved. However, further optimization in the programming is possible, but it is not the subject of this paper.

The behavior of the proposed predictive controller in steady-state operation for a resistive load of 20Ω is shown in Fig. 5. The amplitude of the reference voltage is set to 200 V, and the frequency is 50 Hz. It is shown in the figure that the output voltages are sinusoidal with low distortion. The output voltages and currents with a different amplitude of the reference voltage of 150 V are shown in Fig. 6.

The output voltage, output current, and filter current in one phase are shown in Fig. 7. It is shown that, due to the resistive load, the load current is proportional to the output voltage while the filter current measured at the output of the converter presents high-frequency harmonics which are attenuated by the filter.




Fig. 5. Experimental results: output voltages and currents in steady state for a reference amplitude of 200 V with 20-Ω load. Voltage THD: 2.65%.




Fig. 8. Experimental results: output voltage and output current for a resistive load step from no load to full load.




Fig. 6. Experimental results: output voltages and currents in steady state for a reference amplitude of 150 V with 20-Ω load. Voltage THD: 2.82%.




Fig. 9. Experimental results: output voltage and output current for a resistive-inductive load step.




Fig. 7. Experimental results: output voltage, output current, and filter current in steady state.

The transient behavior of the system for a load step from no load to full load is shown in Fig. 8. Here, a 20-Ω load is connected at time of 0.05 s. It can be seen in this result that the output voltage is not affected by this change in the load. A similar test is shown in Fig. 9 for a resistive-inductive load.




Fig. 10. Diode-bridge rectifier used as nonlinear load. $C = 3000 \mu\text{F}$, $R = 60 \Omega$.

The load, with values $R = 20 \Omega$ and 10 mH, is connected at time 0.1 s. The amplitude of the reference voltage is 200 V for the resistive load and 150 V for the resistive-inductive load.

The diode-bridge rectifier shown in Fig. 10 was used as nonlinear load for the results shown in Fig. 11. Here, the output voltage presents a small distortion, but it is still sinusoidal despite the highly distorted load currents. A noticeable unbalance in the load currents is present in this result due to unbalanced voltages when a nonlinear load is connected. This result could be improved by using a higher sampling frequency, but this solution is difficult to implement due to hardware restrictions. Alternative solutions to improve the quality of the control for nonlinear loads are under consideration.




Fig. 11. Experimental results: output voltages and currents in steady state for a nonlinear load and a reference amplitude of 200 V. Voltage THD: 4.60%.




Fig. 12. Experimental results: derivative-based and observer-based load-current estimations.

Two estimation methods were implemented experimentally, the derivative-based estimation (21) and the observer-based estimation. All the results previously shown were obtained using the load-current observer. In Fig. 12, the performances of both estimators are shown. It can be noted that the derivative-based estimation is very noisy while the observer-based estimation is much cleaner due to the filtering action of the observer. The output voltages obtained using the proposed predictive controller with both estimation methods are shown in Fig. 13 for the same operating conditions. The use of a noisy estimation introduces errors in the calculation of the output-voltage prediction producing distorted voltages, as shown in Fig. 13(a). When comparing this result with the one shown in Fig. 13(b) using the observer, it is clear that the use of the observer enhances the behavior of the control, achieving a lower THD, without the use of additional current measurements. Results from Fig. 13 where obtained using a smaller filter, compared to the results shown in Fig. 5, and consequently present a higher THD value. When the nonlinear load is connected, the error introduced by the derivative-based estimator makes the controller fail to control the output voltage, and the UPS does not work. However, the load-current observer delivers a good estimation, as shown in Fig. 14, allowing for a good control of the output voltages.




Fig. 13. Experimental results. (a) Output voltages using derivative-based load-current estimation. THD = 7.8%. (b) Output voltages using observer-based load-current estimation. THD = 3.8%.




Fig. 14. Experimental results: observer-based load-current estimation for the nonlinear load. (An offset has been added to the measured signals.)




Fig. 15. Experimental results: load current and estimated load current using the observer for a load step. (Top) Using a fast observer. (Bottom) Using a slow observer.

The effect of two different pole placement for the load-current observer is shown in Figs. 15 and 16. A plot of the pole placement for the fast and slow observers is shown in Fig. 17. The load current in one phase of the load is shown in Fig. 15 when a resistive load step is applied at time 0.1 s. A fast observer is used in the upper figure where it is shown how the estimated value is equal to the measured value in a fraction of fundamental cycle. On the other hand, if a slow observer is used, the estimated value reaches the real value after a full




Fig. 16. Experimental results: output voltages for a load step. (Top) Using a fast observer. (Bottom) Using a slow observer.




Fig. 17. Pole placement for fast and slow observers.

cycle. The effect of these differences in the estimation over the output voltage is shown in Fig. 16. Here, a resistive load step is applied at time 0.05 s. While with the fast observer the effect of the load step is a very short drop in the voltages, with the slow observer, there is a noticeable reduction of the voltage amplitude, with respect to the reference amplitude (dashed lines), between times 0.05 and 0.06 s.

VI. CONCLUSION

In this paper, a new and simple control scheme was presented for a three-phase inverter with output *LC* filter. The feasibility of the proposed predictive controller has been demonstrated by implementing it in a laboratory prototype. Results show that the proposed scheme achieves a good voltage regulation with linear loads as well as with nonlinear loads.

The proposed controller has no parameters to adjust; it needs a model of the system for calculating predictions of the con-

trolled variables. The gate-drive signals are generated directly by the controller, so a modulator is not needed.

The output voltage is directly controlled, without using a cascaded control structure, with an inner current-control loop. This allows for a fast dynamic response of the voltage control.

It has been shown that the use of an observer allows for a good estimation of the unknown load current and improves the overall behavior of the system without the need of additional current measurements.

Predictive control presents a different approach for the control of power converters, taking into account the discrete nature of the converters and the microprocessors used for the control. In addition, the high calculation power of the current existing DSPs makes this method very attractive to control power converters.

REFERENCES

- [1] J. M. Carrasco, L. G. Franquelo, J. T. Bialasiewicz, E. Galvan, R. C. PortilloGuisado, M. A. M. Prats, J. I. Leon, and N. Moreno-Alfonso, "Power-electronic systems for the grid integration of renewable energy sources: A survey," *IEEE Trans. Ind. Electron.*, vol. 53, no. 4, pp. 1002–1016, Jun. 2006.
- [2] F. Blaabjerg, R. Teodorescu, M. Liserre, and A. V. Timbus, "Overview of control and grid synchronization for distributed power generation systems," *IEEE Trans. Ind. Electron.*, vol. 53, no. 5, pp. 1398–1409, Oct. 2006.
- [3] J. M. Guerrero, L. Garcia de Vicuna, and J. Uceda, "Uninterruptible power supply systems provide protection," *IEEE Ind. Electron. Mag.*, vol. 1, no. 1, pp. 28–38, 2007.
- [4] O. Kukrer, "Deadbeat control of a three-phase inverter with an output *LC* filter," *IEEE Trans. Power Electron.*, vol. 11, no. 1, pp. 16–23, Jan. 1996.
- [5] M. Kojima, K. Hirabayashi, Y. Kawabata, E. C. Ejiogu, and T. Kawabata, "Novel vector control system using deadbeat-controlled PWM inverter with output *LC* filter," *IEEE Trans. Ind. Appl.*, vol. 40, no. 1, pp. 162–169, Jan./Feb. 2004.
- [6] P. Mattavelli, "An improved deadbeat control for UPS using disturbance observers," *IEEE Trans. Ind. Electron.*, vol. 52, no. 1, pp. 206–212, Feb. 2005.
- [7] P. C. Loh, M. J. Newman, D. N. Zmood, and D. G. Holmes, "A comparative analysis of multiloop voltage regulation strategies for single and three-phase UPS systems," *IEEE Trans. Power Electron.*, vol. 18, no. 5, pp. 1176–1185, Sep. 2003.
- [8] P. C. Loh and D. G. Holmes, "Analysis of multiloop strategies for *LC/CL/LCL*-filtered voltage-source and current-source inverters," *IEEE Trans. Ind. Appl.*, vol. 41, no. 2, pp. 644–654, Mar./Apr. 2005.
- [9] S. Buso, S. Fasolo, and P. Mattavelli, "Uninterruptible power supply multiloop control employing digital predictive voltage and current regulators," *IEEE Trans. Ind. Appl.*, vol. 37, no. 6, pp. 1846–1854, Nov./Dec. 2001.
- [10] A. Kulka, T. Undeland, S. Vazquez, and L. G. Franquelo, "Stationary frame voltage harmonic controller for standalone power generation," in *Proc. Eur. Conf. Power Electron. Appl.*, Sep. 2007, pp. 1–10.
- [11] M. N. Marwali and A. Keyhani, "Control of distributed generation systems—Part I: Voltages and currents control," *IEEE Trans. Power Electron.*, vol. 19, no. 6, pp. 1541–1550, Nov. 2004.
- [12] G. Escobar, A. A. Valdes, J. Leyva-Ramos, and P. Mattavelli, "Repetitive-based controller for a UPS inverter to compensate unbalance and harmonic distortion," *IEEE Trans. Ind. Electron.*, vol. 54, no. 1, pp. 504–510, Feb. 2007.
- [13] G. Escobar, P. Mattavelli, A. M. Stankovic, A. A. Valdez, and J. Leyva-Ramos, "An adaptive control for UPS to compensate unbalance and harmonic distortion using a combined capacitor/load current sensing," *IEEE Trans. Ind. Electron.*, vol. 54, no. 2, pp. 839–847, Apr. 2007.
- [14] G. Willmann, D. F. Coutinho, L. F. A. Pereira, and F. B. Libano, "Multiple-loop *H*-infinity control design for uninterruptible power supplies," *IEEE Trans. Ind. Electron.*, vol. 54, no. 3, pp. 1591–1602, Jun. 2007.
- [15] P. Cortes, M. P. Kazmierkowski, R. M. Kennel, D. E. Quevedo, and J. Rodriguez, "Predictive control in power electronics and drives," *IEEE Trans. Ind. Electron.*, vol. 55, no. 12, pp. 4312–4324, Dec. 2008.

- [16] R. Kennel and A. Linder, "Predictive control of inverter supplied electrical drives," in *Proc. IEEE PESC*, Galway, Ireland, Jun. 2000, pp. 761–766. CD-ROM.
- [17] G. Bode, P. C. Loh, M. J. Newman, and D. G. Holmes, "An improved robust predictive current regulation algorithm," *IEEE Trans. Ind. Appl.*, vol. 41, no. 6, pp. 1720–1733, Nov./Dec. 2005.
- [18] S.-M. Yang and C.-H. Lee, "A deadbeat current controller for field oriented induction motor drives," *IEEE Trans. Power Electron.*, vol. 17, no. 5, pp. 772–778, Sep. 2002.
- [19] Y. Nishida, O. Miyashita, T. Haneyoshi, H. Tomita, and A. Maeda, "A predictive instantaneous-current PWM controlled rectifier with AC-side harmonic current reduction," *IEEE Trans. Ind. Electron.*, vol. 44, no. 3, pp. 337–343, Jun. 1997.
- [20] L. Malesani, P. Mattavelli, and S. Buso, "Robust dead-beat current control for PWM rectifier and active filters," *IEEE Trans. Ind. Appl.*, vol. 35, no. 3, pp. 613–620, May/June 1999.
- [21] J. Mossoba and P. W. Lehn, "A controller architecture for high bandwidth active power filters," *IEEE Trans. Power Electron.*, vol. 18, no. 1, pt. 2, pp. 317–325, Jan. 2003.
- [22] P. Mattavelli, G. Spiazzi, and P. Tenti, "Predictive digital control of power factor preregulators with input voltage estimation using disturbance observers," *IEEE Trans. Power Electron.*, vol. 20, no. 1, pp. 140–147, Jan. 2005.
- [23] A. Nasiri, "Digital control of three-phase series-parallel uninterruptible power supply systems," *IEEE Trans. Power Electron.*, vol. 22, no. 4, pp. 1116–1127, Jul. 2007.
- [24] Y. A.-R. I. Mohamed and E. F. El-Saadany, "An improved deadbeat current control scheme with a novel adaptive self-tuning load model for a three-phase PWM voltage-source inverter," *IEEE Trans. Ind. Electron.*, vol. 54, no. 2, pp. 747–759, Apr. 2007.
- [25] Y. A.-R. I. Mohamed and E. F. El-Saadany, "Robust high bandwidth discrete-time predictive current control with predictive internal model—A unified approach for voltage-source PWM converters," *IEEE Trans. Power Electron.*, vol. 23, no. 1, pp. 126–136, Jan. 2008.
- [26] Y. A.-R. I. Mohamed and E. F. El-Saadany, "Adaptive discrete-time grid-voltage sensorless interfacing scheme for grid-connected DG-inverters based on neural-network identification and deadbeat current regulation," *IEEE Trans. Power Electron.*, vol. 23, no. 1, pp. 308–321, Jan. 2008.
- [27] Q. Zeng and L. Chang, "An advanced SVPWM-based predictive current controller for three-phase inverters in distributed generation systems," *IEEE Trans. Ind. Electron.*, vol. 55, no. 3, pp. 1235–1246, Mar. 2008.
- [28] A. Linder and R. Kennel, "Model predictive control for electrical drives," in *Proc. IEEE PESC*, Recife, Brazil, Jun. 12–16, 2005, pp. 1793–1799.
- [29] E. F. Camacho and C. Bordons, *Model Predictive Control*. New York: Springer-Verlag, 2007.
- [30] G. C. Goodwin, M. M. Serón, and J. D. Doná, *Constrained Control and Estimation*. New York: Springer-Verlag, 2004.
- [31] J. M. Maciejowski, *Predictive Control With Constraints*. Englewood Cliffs, NJ: Prentice-Hall, 2001.
- [32] V. Blasko and V. Kaura, "A new mathematical model and control of a three-phase AC-DC voltage source converter," *IEEE Trans. Power Electron.*, vol. 12, no. 1, pp. 116–123, Jan. 1997.
- [33] R. C. Portillo, M. M. Prats, J. I. Leon, J. A. Sanchez, J. M. Carrasco, E. Galvan, and L. G. Franquelo, "Modeling strategy for back-to-back three-level converters applied to high-power wind turbines," *IEEE Trans. Ind. Electron.*, vol. 53, no. 5, pp. 1483–1491, Oct. 2006.
- [34] J. Kley, G. Papafotiou, K. Papadopoulos, P. Bohren, and M. Morari, "Performance evaluation of model predictive direct torque control," in *Proc. IEEE PESC*, Jun. 2008, pp. 4737–4744.
- [35] M. Veenstra and A. Rufier, "Control of a hybrid asymmetric multilevel inverter for competitive medium-voltage industrial drives," *IEEE Trans. Ind. Appl.*, vol. 41, no. 2, pp. 655–664, Mar./Apr. 2005.
- [36] S. Muller, U. Ammann, and S. Rees, "New time-discrete modulation scheme for matrix converters," *IEEE Trans. Ind. Electron.*, vol. 52, no. 6, pp. 1607–1615, Dec. 2005.
- [37] R. Vargas, J. Rodriguez, U. Ammann, and P. W. Wheeler, "Predictive current control of an induction machine fed by a matrix converter with reactive power control," *IEEE Trans. Ind. Electron.*, vol. 55, no. 12, pp. 4362–4371, Dec. 2008.
- [38] J. Rodríguez, J. Pontt, C. Silva, P. Correa, P. Lezana, P. Cortés, and U. Ammann, "Predictive current control of a voltage source inverter," *IEEE Trans. Ind. Electron.*, vol. 54, no. 1, pp. 495–503, Feb. 2007.
- [39] J. Rodríguez, J. Pontt, C. Silva, M. Salgado, S. Rees, U. Ammann, P. Lezana, R. Huerta, and P. Cortés, "Predictive control of a three-phase inverter," *Electron. Lett.*, vol. 40, no. 9, pp. 561–562, Apr. 29, 2004.
- [40] P. Cortes, J. Rodriguez, P. Antoniewicz, and M. Kazmierkowski, "Direct power control of an AFE using predictive control," *IEEE Trans. Power Electron.*, vol. 23, no. 5, pp. 2516–2523, Sep. 2008.
- [41] M. A. Perez, P. Cortes, and J. Rodriguez, "Predictive control algorithm technique for multilevel asymmetric cascaded h-bridge inverters," *IEEE Trans. Ind. Electron.*, vol. 55, no. 12, pp. 4354–4361, Dec. 2008.
- [42] E. I. Silva, B. P. McGrath, D. E. Quevedo, and G. C. Goodwin, "Predictive control of a flying capacitor converter," in *Proc. Amer. Control Conf.*, New York, Jul. 2007, pp. 3763–3768.
- [43] H. Kwakernaak and R. Sivan, *Linear Optimal Control Systems*. New York: Wiley, 1972.
- [44] B. D. O. Anderson and J. Moore, *Optimal Filtering*. Englewood Cliffs, NJ: Prentice-Hall, 1979.
- [45] P. Cortes, J. Rodriguez, D. E. Quevedo, and C. Silva, "Predictive current control strategy with imposed load current spectrum," *IEEE Trans. Power Electron.*, vol. 23, no. 2, pp. 612–618, Mar. 2008.



Patricio Cortés (S'05–M'08) received the B.Eng. and M.Sc. degrees in electronics engineering in 2004 and the Ph.D. degree in 2008 from the Universidad Técnica Federico Santa María (UTFSM), Valparaíso, Chile.

Since 2003, he has been with the Electronics Engineering Department, UTFSM, where he is currently a Research Associate. In 2007, he visited the Institute of Control and Industrial Electronics, Warsaw University of Technology, Warsaw, Poland. His main research interests include power electronics, adjustable-speed drives, and predictive control. He received the Best Paper Award from the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS for 2007.

His main research interests include power electronics, adjustable-speed drives, and predictive control. He received the Best Paper Award from the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS for 2007.



Gabriel Ortiz was born in Chuquicamata, Chile, on September 13, 1984. He received the M.Sc. degree in 2008. His thesis concerned reconfiguration of regenerative and nonregenerative cascaded multilevel converters under fault condition. He has been working toward the Ph.D. degree in the Power Electronic Systems Laboratory, Eidgenössische Technische Hochschule Zürich, Zürich, Switzerland, since 2009.

Since early 2007, he has also been with the power electronics group of the Electronics Engineering Department, Universidad Técnica Federico

Santa María, Valparaíso, Chile.



Juan I. Yuz (S'01–M'06) was born in Valparaíso, Chile, in 1975. He received the Ingeniero Civil Electrónico and M.S. degrees in electronics engineering from the Universidad Técnica Federico Santa María (UTFSM), Valparaíso, in 2001, and the Ph.D. degree in electrical engineering from The University of Newcastle, Newcastle, Australia, in 2006.

He currently holds a research position with the Automatic Control Group in the Electronics Engineering Department, UTFSM. His research areas are in control and identification of sampled-data

systems.

Dr. Yuz was the recipient of the Best Electronics Engineering Student Award from UTFSM in 2001.



José Rodríguez (M'81–SM'94) received the B.Eng. degree in electrical engineering from the Universidad Técnica Federico Santa María (UTFSM), Valparaíso, Chile, in 1977, and the Dr.-Ing. degree in electrical engineering from the University of Erlangen, Erlangen, Germany, in 1985.

Since 1977, he has been with the Electronics Engineering Department, UTFSM, where from 2001 to 2004, he was the Director and, currently, is a Professor. From 2004 to 2005, he was the Vice-Rector of Academic Affairs, and since 2005, has been the Rector at UTFSM. During his sabbatical leave in 1996, he was responsible for the Mining Division, Siemens Corporation, Santiago, Chile. He has extensive consulting experience in the mining industry, particularly in the application of large drives such as cycloconverter-fed synchronous motors for SAG mills, high-power conveyors, and controlled ac drives for shovels and power-quality issues. He has directed more than 40 R&D projects in the field of industrial electronics. He has coauthored more than 250 journal and conference proceedings papers and contributed one book chapter. His research group has been recognized as one of the two Centers of Excellence in Engineering in Chile from 2005 to 2008. His main research interests include multilevel inverters, new converter topologies, and adjustable-speed drives.

Prof. Rodríguez has been an active Associate Editor of the IEEE TRANSACTIONS ON POWER ELECTRONICS and IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS, since 2002. He has served as Guest Editor for the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS in five instances [Special Sections on matrix converters (2002), multilevel inverters (2002), modern rectifiers (2005), high-power drives (2007), and predictive control of power converters and drives (2008)]. He received the Best Paper Award from the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS for 2007.



Sergio Vazquez (S'04–M'08) was born in Seville, Spain, in 1974. He received the B.S. and M.S. degrees in industrial engineering from the University of Seville (US), Seville, in 2003 and 2006, respectively.

In 2002, he was with the Power Electronics Group, University of Seville, working on R&D projects. He is currently an Assistant Professor with the Department of Electronic Engineering, US. His research interests include electronic power systems, modeling, modulation and control of power electronic converters, and power quality in renewable generation plants.

plants.



Leopoldo G. Franquelo (M'84–SM'96–F'05) was born in Málaga, Spain. He received the M.Sc. and Ph.D. degrees in electrical engineering from the University of Seville (US), Seville, Spain, in 1977 and 1980, respectively.

Since 1978, he has been with the US, where he was first a Research Assistant, then an Associate Professor in 1982, the Director of the Electronics Engineering Department from 1998 to 2005, and has been a Professor in the same department since 1986.

He is leading a large research and teaching team in Spain. In the last five years, his group activity can be summarized as follows: 45 publications in international journals, 170 in international conference proceedings, ten patents, advisor for ten Ph.D. dissertations, and 96 R&D projects. His current research interests include modulation techniques for multilevel inverters and applications to power electronic systems for renewable energy systems.

Dr. Franquelo was the Vice President of the IEEE Industrial Electronics Society (IES) Spanish Chapter from 2002 to 2003 and a Member-at-Large of the IES AdCom from 2002 to 2003. He was the Vice President for Conferences of the IES from 2004 to 2007, of which he has also been a Distinguished Lecturer since 2006. He has been an Associate Editor for the IEEE TRANSACTIONS ON INDUSTRIAL ELECTRONICS since 2007. Since January 2008, he has been the President Elect of the IES.